



DEKALB COUNTY
Department of Watershed Management
Watershed Protection and Compliance Division
330 W. Ponce de Leon Avenue-3rd Floor, Decatur, GA 30030
(404) 687-7150 • Fax (404) 687-7167
F.O.G. Program



FORM 2
May 2012

Specifications and Plumbing Requirements for Interior Grease Traps:

- Minimum size 100 pounds
- Be made of corrosion-resistant coated metal;
- Be properly sized based on the results of an inspection and FOG evaluation, Form A;
- Contain properly installed and functioning baffle walls and other flow control devices necessary to achieve the appropriate retention time;
- Have at least a thirty-minute interior retention time before gray water is discharged into the sewer system;
- Tie all of the fresh air fixtures to the FOG interceptor;
- Have fifteen-foot distance between the FOG interceptor and the last fresh air fixture and have a proper flow control device;
- Be Plumbing Drainage Institute rated, be accessible for inspection, and be installed in accordance with the manufacturer's specifications by a licensed plumber and not a representative and/or an apprentice of the licensed plumber;
- Mechanical FOG interceptors are prohibited.

