

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Spills that Entered Waters of the US/State

SSO NO.	Date/Time		Type & Volume			Location		MH/Line		Cause/Source		Water Body		Flow Restoration			Notification Dates			Update Comments
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole/Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up	
1	1/9/2013	20:02	n		5,120	2365 Leisure Lake Drive	Dunwoody	359-s062	8	GR	Grease blocked line	Leisure Lake	L	1/9/2013	22:10	Rodded main 120 feet to restore flow.	01/10/13	01/10/13	No defects found on CCTV	
2	1/10/2013	8:57	n		8,235	5772 Keystone Way	Decatur	073-s004	10	GR	Grease blocked line	Pole Bridge Creek	A	1/10/2013	12:00	Pressure washed main upstream 175 feet to remove grease and restore flow. Pressure washed additional 200 feet downstream to remove roots from invert and line.	01/11/13	01/11/13	The site is an engineering project for access to the wetlands that was built over our sewer system and currently is inaccessible.	Correct address and city is shown for this spill. Site is off road and had no valid address.
3	1/16/2013	15:29	n		4,080	4090 Sautee Trail	Conley	020-s011	8	GR	Grease blocked line	Crawford Lake	L	1/16/2013	16:37	Pressure washed 800 feet to restore flow. Pressure washed area again when manholes did not completely go down.	01/17/13	01/17/13	CCTV showed heavy grease that was removed by pressure wash and root cutters.	
4	1/17/2013	12:35	n		3,525	6422 Stewart Lake Court	Lithonia	119-s003	10	BRK LN/STR	Broken line in creek bank.	Stewart Lake	L	1/17/2013	16:30	Crew made point repair to broken 10 inch sewer line which contained 2 breaks. 23 feet of pipe was replaced 1-17-13.	01/17/13	01/18/13	Pole camera revealed no defects or issues	
5	1/22/2013	14:44	n		5,840	5245 Mainstreet Park Drive	Stone Mountain	033-s131	8	BRK LN/STR	Broken line in creek bank.	Barbashela Creek	N	1/22/2013	17:10	Point repair made on line buried in creek bank.	01/23/13	01/23/12		Correct time on reprot as 5 day letter in error
6	1/23/2013	11:12	n		320	4034 Sautee Trail	Conley	020-s014	8	GR	Grease blocked line	Blue Creek	Y	1/23/2013	11:30	Cleaning contractor discovered spill when doing follow-up from previous spill near this location..	01/24/13	01/24/13	CCTV of relined sewer main showed no problems	Area was already being cleaned.
7	1/24/2013	10:34	n		4,300	4254 English Oaks Drive	Doraville	338-s003	8	UNK	Unknown blockage of line caused manhole overflow.	North Fork Peachtree Creek	2	1/24/2013	14:09	Rodded manhole to restore flow followed by pressure washing the line 25 feet.	01/25/13	01/25/12		Call came in as water leak.and that crew reported sewer spill.
8	1/24/2013	15:19	n		5,320	4601 Snapfinger Woods Drive	Decatur	008-s004	10	GR	Grease blocked line	Snapfinger Creek	Y	1/24/2013	16:35	Rodded 10 inch main 110 feet to clear blockage and restore flow.	01/24/13	01/25/13		
9	1/29/2013	9:13	n		1,480	3176 Big Springs Court	Decatur	092-s077	8	RT	Roots blocked line	Cobbs Creek	Y	1/29/2013	10:27	Rodded 8" main 225 feet to clear blockage and restore flow. Root cut main and clear now.	01/30/13	01/30/13		
10	1/29/2013	13:48	n		900	6361 Peachtree Industrial Blvd.	Doraville	342-s079	8	GR	Grease blocked line	Nancy Creek	N	1/29/2013	14:33	Pressure washed main 37 feet upstream to manhole 342-s079 and restored flow.	01/30/13	01/30/13		
11	1/31/2013	7:09	n		8,100	3042 Hathaway Court	Chamblee	269-s218	8	GR	Grease blocked line	Lake Louise	Y	1/31/2013	9:24	Pressure washed 8 inch line 450 feet upstream from manhole 264-s010 to restore flow.	01/31/13	02/02/13		
12	1/31/2013	11:12	n		5,520	3352 North Druid Hills Road	Decatur	102-s113	8	VAND	Graffiti artist put spray cans in main from manhole which collected grease and blocked main.	Burnt Fork Creek	N	1/31/2013	13:30	Removed cans from main and pressure washed line 288 feet. Point repair made on 3-13-13 to abandoned stub on golf course where sewer surfaced.	01/31/13	02/11/13	Smoke testing to determine location for point repair	
13	1/31/2013	14:35	n		8,800	2871 Glenwood Avenue	Atlanta	171-s416	8	BRK LN/STR	Manhole was leaking at joint	Buena Vista Lake	Y	1/31/2013	18:15	Bypass pumps set up after excavation revealed missing line segment and storm drain conflict. Manhole leak repaired.	02/01/13	02/01/13		Calls made 2 days earlier but no sewer spill or issue was found based on inspections at the time.
14	2/1/2013	12:15	n		1,300	3355 Northeast Expressway	Atlanta	267-s044	8	GR	Grease blocked line	North Fork Peachtree Creek	N	2/1/2013	13:20	Pressure wash main 168 feet to clear blockage	02/01/13	02/04/13		
15	2/2/2013	17:38	n		5,040	1736 Jericho Court	Tucker	167-s012	10	GR	Grease blocked line	South Fork Peachtree Creek	A	2/2/2013	18:50	Pressure washed main 300 feet to restore flow.	02/03/13	02/04/13	CCTV revealed defects at 15 and 88 feet. Relining project due to surface having a tennis court over the line.	
16	2/10/2013	15:23	n		5,220	2333 North Peachtree Way	Dunwoody	370-s054	8	GR	Grease blocked line	Leisure Lake	L	2/10/2013	16:50	Pressure washed 60 feet of main to clear blockage.	02/11/13	02/11/13	Crew replaced 14 feet of 8 inch clay pipe.	Corrected address to 2333 North Peachtree Way.
17	2/11/2013	9:20	n		4,500	8644 Covington Highway	Lithonia			LFT STN FLR	Debris covered transducer	Unknown lake at Vulcan Materials	L	2/11/2013	9:25	Cleaned transducer and restored lift station operations to normal.	02/11/13	02/11/13		
18	2/12/2013	8:51	n		1,600	2396 Ledgewood Drive	Atlanta	354-s215	8	RT	Roots blocked line	Nancy Creek	Y	2/12/2013	10:11	Rodded main 160 feet to restore flow.	02/12/13	02/13/13		
19	2/12/2013	10:48	n		2,880	2063 Jordan Terrace	Atlanta	235-s209	8	GR	Grease blocked line	North Fork Peachtree Creek	B	2/12/2013	12:00	Pressure washed 8 inch main 75 feet to restore flow.	02/12/13	02/13/13		
20	2/14/2013	10:29	n		3,440	1498 Clairmont Road	Decatur	060-s130	8	GR	Grease blocked line	South Fork Peachtree Creek	Y	2/14/2013	11:55	Pressure washed main 5 feet to restore flow.	02/15/13	02/15/13	CCTV revealed no defects	
21	2/14/2013	18:59	n		4,320	3571 Buford Highway	Atlanta	203-s205	8	GR	Grease blocked line	North Fork Peachtree Creek	A	2/14/2013	21:35	Rodded sewer line 2 feet to restore flow.	02/15/13	02/15/13	CCTV revealed no defects	Volume calculation wrong initially.
22	2/15/2013	8:52	n		4,080	2836 Thornbriar Road	Doraville	262-s096	8	GR	Grease blocked line	Peachtree Branch	N	2/15/2013	10:00	Pressure washed main 40 feet and cleared blockage.	02/16/13	02/19/13	CCTV revealed no defects	
23	2/16/2013	9:32	n		1,240	3854 West Nancy Creek Place	Atlanta	327-2028	8	RT	Roots blocked line	Perimeter Creek	N	2/16/2013	10:34	Pressure washed main 120 feet and cleared heavy debris blockage at 60 feet.	02/17/13	02/19/13	CCTV revealed no defects	Corrected Waterbody from Nancy to Perimeter Creek

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Spills that Entered Waters of the US/State

SSO NO.	Date/Time		Type & Volume			Location		MH/Line		Cause/Source		Water Body		Flow Restoration			Notification Dates			Update Comments
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole/Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up	
24	2/19/2013	14:51	n		1,960	2739 Shallowford Road	Atlanta	246-s041	8	GR	Grease blocked line	North Fork Peachtree Creek	N	2/19/2013	15:40	Pressure washed the main 55 feet to clear blockage and restore flow.	02/20/13	02/20/13	CCTV revealed section flowing backwards because of invert. Repair completed 3-19-13.	
25	2/21/2013	14:05	n		3,400	2333 North Peachtree Way	Dunwoody	310-s091	8	BRK LN/STR	Broken 8 inch line leaking	Leisure Lake	L	2/21/2013	15:30	Crew built containment area and replace 12 feet of 8 inch pipe.	02/22/13	02/22/13	CCTV found small amount of sand in line which was removed by pressure washing 200 feet..	Crew found leak when doing follow-up line cleaning.
26	2/24/2013	17:35	n		9,225	3606 Stewart Road	Doraville	311-s075	10	RTDB	Roots and rock debris blocked line	North Fork Peachtree Creek	Y	2/24/2013	21:00	Pressure washed main 38 feet and unable to clear. Rodded main with 5 inch bit and restored flow from blockage at 38 feet.	02/25/13	02/25/13		
27	2/27/2013	7:56	n		9,730	3526 Donaldson Drive	Brookhaven	306-s102	10	GRRT	Grease and roots blocked main	Nancy Creek	C	2/27/2013	10:15	Crew set up vacuum truck to control spill from manhole at 10:15. Pressure washed line 78 feet to remove blockage.	02/27/13	02/28/13		
28	3/4/2013	16:15	n	YES	92,250	6380 Peachtree Industrial Blvd.	Doraville	342-s022	12	BRK LN/STR	Line broken in creek	Nancy Creek	N	3/4/2013	23:45	By-pass pump set up after repeated attempts to clear the line failed. Point repair made 3-5-13.	03/05/13	03/06/13		
29	3/6/2013	9:35	n		9,300	3930 East Brookhaven Drive	Brookhaven	240-s057	8	GR	Grease blocked line	Capital City Club Lake	L	3/6/2013	12:30	Pressure washed 8 inch line 285 feet to clear blockage at 200 and restore flow. Chipped asphalt from buried manhole that was overflowing.	03/07/13	03/07/13		East was left off the address in the 5 day letter.
30	3/7/2013	13:10	n		2,160	366 Greenwood Avenue	Decatur	213-s089	8	GR	Grease blocked line	Shoal Creek	W	3/7/2013	14:04	Rodded from manhole to manhole 30 feet across creek to restore flow.	03/07/13	03/08/13		
31	3/7/2013	17:24	n		3,840	1624 Brockett Road	Tucker	167-s010	8	RTDB	Roots and debris blocked line	South Fork Peachtree Creek	A	3/7/2013	18:28	Rodded sewer main 123 feet to remove blockage and restore flow.	03/08/13	03/08/13	Further investigation showed line was broken down.	
32	3/11/2013	10:08	n		6,475	1155 Zonolite Road	Atlanta	107-s037	8	GR	Grease blocked line	South Fork Peachtree Creek	U	3/11/2013	14:27	Rodded main 54 feet and restored flow.	03/12/13	03/12/13	Crew cleared easement to build access road and restore area.	
33	3/11/2013	17:57	n		4,740	115 Green Street	Decatur	214-s013	8	GRDB	Grease and Debris blocked line	Shoal Creek	W	3/11/2013	19:16	Pressure washed main 160 feet to restore flow.	03/12/13	03/13/13	Investigated line and found manhole without invert and perforated lids which appear to be causing capacity issue.	Updated year, initial time and volume of spill.
34	3/12/2013	15:28	n		2,160	3954 Memorial College Avenue	Clarkston	043-s202	8	GR	Grease blocked Line	Snapfinger Creek	D	3/12/2013	16:22	Rodded main 10 feet and restored flow.	03/13/13	03/13/13	Review showed several multi-family complexes on line causing multiple grease spills. Education needed. Issued trunk line cleaning order on 4-8-13.	
35	3/18/2013	10:57	n		6,000	3415 Riverview Chase Way	Ellenwood	038-s084	8	GRDB	Grease and debris blocked line	Conley Creek	N	3/18/2013	12:37	Pressure washed 600 feet to clear line and blockage at 230 feet which restored flow.	03/19/13	03/20/13	CCTV revealed minor debris and roots which were removed from 340 feet of line. Small belly noted at 90 feet but did not impact flow.	Added to CARL list on 4-8-13 for annual cleaning.
36	3/19/2013	15:05	n		5,000	1056 Happy Valley Trail	Atlanta	145-s087	10	GRDB	Grease and Debris blocked line	Entrenchment Creek	A	3/19/2013	15:45	Rodded main 60 feet to clear grease and rags from 10 inch line and restore flow.	03/20/13	03/20/13		
37	3/20/2013	10:54	n		1,050	118 Lucerne Street	Decatur	NA	8	OTH	Sewer line ran through storm drain and leaking inside storm drain.	South Fork Peachtree Creek	U	3/20/2013	12:39	Pressure washed main to clear blockage and stop leak.	03/21/13	03/21/13	CCTV 200 feet showed several bellies and offset joints which show need for pipe-bursting.	C&M to get open market quote for pipe-bursting.
38	3/20/2013	12:22	n		920	5282 Rockborough Trail	Stone Mountain	038-s056	8	GR	Grease blocked downstream manhole invert	Barbashela Creek	N	3/20/2013	13:08	Pressure washed downstream manhole to remove grease at invert and also 600 feet of line to restore flow.	03/21/13	03/20/13	CCTV revealed small amount of grease which was removed.	
39	3/21/2013	9:33	n		290	5464 Sigman Street	Stone Mountain	074-s036	8	GR	Grease blocked main	Wohelo Lake	N	3/21/2013	10:31	Line holding and back-up revealed a lateral leaking in a storm drain. Point repair to be made.	03/22/13	03/22/13		
40	3/21/2013	11:30	n		7,480	2974 Aspen Woods Entry	Doraville	340-s001	8	GRDB	Grease and rags blocked main.	Nancy Creek	2	3/21/2013	13:06	Rodded main line 62 feet to remove blockage.	03/22/13	03/22/13	Existing engineering project for multi-family site feeding directley to this manhole.	
41	3/29/2013	8:11	n		1,980	4791 Summerford Drive	Dunwoody	362-s011	8	RT	Roots blocked main	Nancy Creek	Y	3/29/2013	9:50	Rodded 8 inch main 70 feet to clear blockage and restore flow.	03/29/13	04/01/13	CCTV 489 feet and root cut to remove all roots. Main is clear and flowing.	

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Spills that Entered Waters of the US/State

SSO NO.	Date/Time		Type & Volume			Location		MH/Line		Cause/Source		Water Body			Flow Restoration			Notification Dates			Update Comments
	Date Spill Reported to DWM	Time Spill Reported to DWM	Fish Kill	Major Spill	Estimated Quantity, gals	Address of Spill	City	Manhole/Structure #	Pipe Size	Cause	Source	Receiving Stream or Waterbody	Tributary	Restoration Date	Restoration Time	Flow Restoration Action	24 hour Notice	5 Day Letter	Additional Follow-up		
42	3/29/2013	12:07	n		4,440	669 South Deshon Road	Stone Mountain	160-s401	8	GR	Grease blocked main	Crooked Creek	N	3/29/2013	13:21	Rodded main 225 feet downstream and could not remove blockage. Rodded upstream from dry manhole 18 feet and restored flow.	03/29/13	04/01/13	CCTV 444 feet and revealed roots and heavy grease which were removed and cleaned..		

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Overflow (Surface Spills)													
Overflow #	Date/Time		Quantity in Gallons	Location		Cause/Source		Flow Restoration			Number	Results	
	Date Spill Reported to DWM	Time Spill Reported to DWM		Address of Spill	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action		Service Request	Inspection Results
S01-13	01/20/13	8:51	1,060	4441 Sentry Drive	Tucker	DB	Debris (sand and rocks) blocked main	01/20/12	9:44	Pressure washed main 25 feet to clear blockage.	1303072		
S02-13	01/22/13	12:09	4,230	4776 Snapfinger Woods Drive	Decatur	GR	Grease blocked line	01/22/13	13:43	Rodded 10 inch line 135 feet from manhole 008-s044 to restore flow.	1303274		Spill in remote area not accessible to equipment.
S03-13	01/23/13	14:26	1,020	1883 Moore Creek Lane	Conley	GR	Grease blocked line	01/23/13	14:43	Cleaned main line 225 feet with pressure wash and root cutter to restore flow.	1303537		
S04-13	01/30/13	9:36	150	5765 Southland Walk	Stone Mountain	GR	Grease blocked main and manhole	01/30/13	12:00	Rodded 8 inch main 1 foot to restore flow.	1304776	CCTV revealed the need to make a point repair on this line to correct a bad installation job where the backfill contained bricks.	Point repair completed 2-16-13. Additional 168 feet cleaned with CCTV.
S05-13	02/06/13	14:00	20	3269 Rockmill Drive	Ellenwood	GR	Grease blocked main	02/06/13	15:00	Pressure washed main 400 feet to restore flow.	1305788	Inspection showed heavy grease and roots which were removed.	Added to CARL list for routine cleaning every 6 months.
S06-13	02/11/13	15:14	15	1526 Idlehour Drive	Tucker	RT	Roots blocked lateral.	02/11/13	16:20	Rodded cleanout 10 feet to restore flow. Pressure washed 176 feet also.	1306566	Found roots and area to make a point repair	Made point repair on 2-21-13.
S07-13	02/13/13	8:30	10	1907 Shalimar Drive	Atlanta	GRDB	Grease and rags blocked line	02/13/13	10:01	Pressure washed main 200 feet upstream from 204-s029 to restore flow.	1306787	Found private manhole with three lines in it. One line was broken and allowed sewage to escape from surcharged manhole. Report made to Health Department.	
S08-13	02/13/13	14:18	4,680	4367 Buford Highway	Atlanta	GRDB	Grease and rocks blocked line	02/13/13	16:15	Pressure washed main 275 feet and blockage located 100 feet from 245-s201.	1306868	Pressure washed main 275 feet and blockage located 100 feet from 245-s201	Needs Relining.
S09-13	02/12/13	21:40	150	4902 Hidden Branches Drive	Dunwoody	RT	Roots blocked line	02/17/13	23:15	Rodded main 150 feet and hit roots at 120 feet to restore flow.	1307602	Evidence of spill from cleanout upon arrival to clear main blocked with roots.	Rodded roots to remove from stub.
S10-13	02/19/13	10:44	50	4398 Carrolwood Drive	Decatur	BRK LN/STR	Stub broken down with roots	02/19/13	14:30	Rodded laterals and determined stub broken down.	1307718	6" stub was broken done.	Point repair made on 2-20-13 by relocating the stub from the manhole.
S11-13	02/21/13	14:40	100	3947 Duncannon Court	Chamblee	RT	Roots blocked line	02/21/13	21:00	Rodded and pressure washed main to remove blockage at 10.5 feet and restore service.	1308217	Found Heavy roots to be the cause of blockage. Point repair with 10 feet of 8 inch line replaced on 2-25-13.	No spill initially and during pressure washing approximately 100 gallons came out of pipe.
S12-13	03/02/13	8:15	20	4535 Hugh Howell Road	Tucker	BRK LN/STR	Broken Force Main	03/02/13	10:00	Repaired another section of force main after station turned off.	1309739	Deteriorated forcemain.	Part of major force main replacement project out for bid now.
S13-13	03/04/13	20:50	175	2175 Capehart Circle	Atlanta	GRRT	Heavy grease and roots blocked line.	03/04/13	22:50	Pressure washed 275 feet of main 7 times to restore flow.	1310142	Follow-up CCTV and pressure washed/root cut to remove all grease, sand and roots from 8 inch main. Flowing good now.	
S14-13	03/09/13	9:47	2,100	1102 Village Circle	Stone Mountain	GR	Grease blocked line causing manhole overflow	03/09/13	10:22	Rodded manhole 42 feet to clear blockage and restore flow.	1310936	CCTV on 3-16-13 found roots and heavy grease which were removed.	Place on CARL list for 6 month cleaning interval.
S15-13	03/10/13	12:42	1,560	3256 Brisbane Way	Lithonia	RT	Roots blocked main	03/10/13	13:08	Rodded main 6 feet upstream to restore flow.	1311014	CCTV showed need for a point repair	Point repair completed 3-21-13
S16-13	03/11/13	15:30	3	1882 Janet Lane	Decatur	RTDB	Roots blocked lateral and during cleaning 3 gallons came out.	03/11/13	16:45	Rodded lateral from property line cleanout 24 feet to remove blockage and during course of work 3 gallons came out.	1311241	Stub repair needed.	Repair completed 3-12-13

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Overflow (Surface Spills)													
Overflow #	Date/Time		Quantity in Gallons	Location		Cause/Source		Flow Restoration			Number	Results	
	Date Spill Reported to DWM	Time Spill Reported to DWM		Address of Spill	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action		Service Request	Inspection Results
S17-13	03/12/13	18:15	75	4639 Huntsman Bend	Decatur	GR	Grease blocked main causing cleanout overflow	03/12/13	21:30	Rodded sewer main 5 feet to restore flow	1311533	CCTV and pressure washed 843 feet.	Main flowing well.
S18-13	03/18/13	8:00	7	2301 Dresden Drive	Chamblee	BRK LN/STR	Broken line next to creek from tree falling on line	03/18/13	12:00	Repaired broken line with FERNCO and cement	1312489	Tree removed which had redirected creek flow. Point repair and line raised on 3-18-13. Rubble placed around manhole to prevent further erosion. CCTV 480 feet revealed no problems.	Spill contained in depression next to line and did not enter creek.
S19-13	03/20/13	16:56	120	3818 Harts Mill Lane	Atlanta	GRDB	Grease and Debris (small rocks) blocked line.	03/20/13	17:40	Rodded main 120 feet to restore flow followed by pressure washing 200 feet.	1312941	CCTV on 3-29-13 showed roots which were removed from 483 feet of line.	Main flowing well.
S20-13	03/26/13	10:40	3	3712 River Lake Shore	Ellenwood	GR	Grease blocked main causing minor manhole overflow.	03/26/13	11:20	Rodded main from dry manhole 10 feet to restore flow.	1313796	No problems found with manhole on 3-27-13. CCTV 210 feet on 4-4-13. Manhole downstream found with heavy debris in it and cleaned on _____.	
S21-13	03/27/13	16:05	50	669 Antietam Drive	Stone Mountain	GRRT	Grease and roots blocked line causing cleanout overflow and building back-up.	03/27/13	19:00	Rodded 8 inch main 60 feet followed by pressure washing 275 feet to restore flow.	1314217	CCTV on 4-2-13 for 315 feet which included root cutting of 1 section upstream to remove heavy roots.	Building back-up B06-13 created also

DeKalb County Department of Watershed Management Consent Decree SSO Tracking Sheet

Building Back-up Report

Building Back-up #	Date/Time		Quantity in Gallons (est.)	Location		Cause/Source		Flow Restoration			Number	Actions				
	Date Spill Reported to DWM	Time Spill Reported to DWM		Address of Spill	City	Cause	Source/Additional Description	Restoration Date	Restoration Time	Flow Restoration Action	Service Request	Cleaning Service	Inspection Results	Additional Follow-up	Faulty Home Plumbing or Not to Code	Update Comments
B01-13	01/16/13	1:43	20	3119 Pheasant Drive	Decatur	GRDB	Grease, rags and a 4 inch plug blocked line.	01/16/13	3:15	Rodded 8 inch main 63 feet to remove blockage.	1302370	No	CCTV line showed grease and roots	Pressure wash and root cut 423 feet of 8 inch sewer main.	X	Sewer main inspected and no issues found. Flow is good. Sent backwater valve letter 2-20-13.
B02-13	01/30/13	21:32	50	1449 West Rock Court	Stone Mountain	GR	Grease blocked line.	01/31/13	3:00	Rodded sewer main 10 feet downstream from manhole to restore flow.	1304775	No	Pressure washed main 750 feet SR1304787	CCTV results found no issues	X	Sent backwater valve letter 2-12-13.
B03-13	02/08/13	15:40	50	2982 Highland Park Circle	Lithonia	GR	Grease blocked line.	02/08/13	20:30	Pressure washed sewer main 150 feet and lateral to restore flow from heavy grease blockage	1306177	Yes	Pressure washed main 150 feet SR1306677	CCTV 480 feet and found no issues	X	Sent backwater valve letter 2-12-13.
B04-13	02/13/13	16:45	20	3213 Pheasant Drive	Decatur	GRRTDB	Grease, roots and rags blocked line	02/13/13	18:00	Rodded sewer main 75 feet and pressure washed sewer main 200 feet.	1306938	Customer called oiw service	Pressure washed main 200 feet SR1306438	CCTV 965 feet and found roots in line that were removed	X	Sent backwater valve letter 2-20-13.
B05-13	03/24/13	8:09	50	3592 Orbit Court	Ellenwood	GR	Grease blocked line.	03/24/13	9:12	Rodded main 217 feet to restore flow.	1313453	Yes	CCTV on 3-29-13 for 594 feet which included removing a small amount of roots.	Pressure washed main 217 .	X	
B06-13	03/27/13	16:05	50	669 Antietam Drive	Stone Mountain	GRRT	Grease and roots blocked line causing cleanout overflow and building back-up.	03/27/13	19:00	Rodded 8 inch main 60 feet followed by pressure washing 275 feet to restore flow.	1314217	Yes	CCTV revealed heavy roots on 4-2-13 which were removed.		X	Surface sipll S-21-13 also created
B07-13	03/29/13	10:30	50	2641 Apple Orchard Road	Atlanta	RT	Roots blocked main.	03/29/13	16:00	Root cut 8 inch main 85 feet to restore flow.	1314498	Yes	Pressure washed main 225 feet. CCTV revealed a small hole in the main near 24 feet. Point repair to be completed.		X	